



Horizontal installation



Vertical installation



7	1	Compact steam trapping station w/ float trap	CTS4U + UFS32		
6	1	Y Strainer	IS140		
5	1	Globe valve	GV32B		
4	1	Check valve	RD40-RT25		
3	1	Double window sight glass	DW40		
2	1	Window sight glass	SW12		
1	1	Float and thermostatic steam trap	FLT		
Ref.	Quant.	Designation	Model	Size	Remarks / Code



Proc. O.490

Description

HUMIDITY SEPARATOR
Steam trap station

Des.N°.

ADPC.01.2167

Rev.: 02 Em: 22.11.16

Page: 1 de 1